


Report Bottling
 Company Thermal Recon
 Address Crestwood, KY. 40014
 Phone (502) 693-7626
 Website thermalrecon.com



Author	Mike Fitzpatrick	Date	5/4/2023	Time	22:30
Device	Sonascreen				
Software	V1.2.444				

Summary	All leaks verified and tagged.				
Number of measurement	17				
Comment	Sample inspection. Time on site approx. 45 minutes.				
Costs per volume	0.85 USD/1,000ft ³			Energy Costs	\$0.12
Running time per year	8736 h			CO2 Emission	0.9 lb/kWh
Overall leakage per year	14651 1,000 ft ³	=	27.95219 cfm	Gas type	Air
Overall costs per year	\$12,453.71			Currency	USD
CO2 emissions per year	91872 lb CO2			Volume Unit	cfm

	Priority 1	Priority 2	Priority 3	Priority 4	Priority 5
Number of leakages	9	7	0	0	1
Leakage rate in cfm	24.518	3.434	0.000	0.000	0.000




Disclaimer: Sonotec GmbH estimates leakage rates based on empirical determinations. Sonotec GmbH is in no way liable for the accuracy of these estimates, for the decisions made on the basis of the results obtained and for the achievement of objectives. In any case, the user bears full responsibility and is liable for all actions or non-actions derived from the results.


Report Bottling
 Company Thermal Recon
 Address 7507 Sunset Ln.
 Crestwood, KY. 40014





Summary of leakages					
ID	Leak rate	Loss/year	Priority	Repaired	
2023-05-03_09-04-22.tdms	3.26393 cfm	1,454.20	1	1	⊗
2023-05-03_09-06-30.tdms	1.44645 cfm	644.44	1	1	⊗
2023-05-03_09-07-48.tdms	.61813 cfm	275.40	2	2	⊗
2023-05-03_09-08-45.tdms	.66347 cfm	295.60	2	2	⊗
2023-05-03_09-11-52.tdms	1.20922 cfm	538.75	1	1	⊗
2023-05-03_09-13-34.tdms	.59360 cfm	264.47	2	2	⊗
2023-05-03_09-14-45.tdms	1.10497 cfm	492.30	1	1	⊗
2023-05-04_10-15-08.tdms	5.30451 cfm	2,363.35	1	1	⊗
2023-05-04_10-19-58.tdms	5.01088 cfm	2,232.53	1	1	⊗
2023-05-04_10-25-19.tdms	.81683 cfm	363.93	1	1	⊗
2023-05-04_10-27-22.tdms	.43519 cfm	193.89	2	2	⊗
2023-05-04_10-31-35.tdms	.25615 cfm	114.12	2	2	⊗
2023-05-04_10-36-07.tdms	.57633 cfm	256.78	2	2	⊗
2023-05-04_10-43-41.tdms	2.63055 cfm	1,172.01	1	1	⊗
2023-05-04_10-45-47.tdms	3.73097 cfm	1,662.28	1	1	⊗
2023-05-04_10-58-53.tdms	.000 cfm	0.00	5	5	⊗
2023-05-04_11-00-24.tdms	.29103 cfm	129.66	2	2	⊗

Disclaimer: Sonotec GmbH estimates leakage rates based on empirical determinations. Sonotec GmbH is in no way liable for the accuracy of these estimates, for the decisions made on the basis of the results obtained and for the achievement of objectives. In any case, the user bears full responsibility and is liable for all actions or non-actions derived from the results.

ID	2023-05-04_10-19-58.tdms	Attribute	Value
	Loss (USD/a)	2232.53	
	Leak rate (cfm)	5.01088	
	Level (dB)	106.4	
	Pressure (psi)	90	
	Distance (ft)	1.00	
	Gas type	Air	
	Machine		
	Component		
	Priority	1	
	Repair recommended	Yes	
	Repair done	No	
	Repairman		
	Repair date		
<p>Line 7 Section 3, Air Dyer.</p>			

ID	2023-05-04_10-15-08.tdms	Attribute	Value
	Loss (USD/a)	2363.35	
	Leak rate (cfm)	5.30451	
	Level (dB)	106.7	
	Pressure (psi)	90	
	Distance (ft)	1.00	
	Gas type	Air	
	Machine		
	Component		
	Priority	1	
	Repair recommended	No	
	Repair done	No	
	Repairman		
	Repair date		
<p>Comment Line 2, Section 4 Coupling on backside.</p>			

ID	2023-05-04_10-45-47.tdms	Attribute	Value
	Loss (USD/a)	1662.28	
	Leak rate (cfm)	3.73097	
	Level (dB)	105.7	
	Pressure (psi)	90	
	Distance (ft)	1.00	
	Gas type	Air	
	Machine		
	Component		
	Priority	1	
	Repair recommended	Yes	
	Repair done	No	
	Repairman		
	Repair date		
	Comment Line 3, Section 2. This is a bolt in a t fitting that is leaking next to an air dryer.		

ID	2023-05-04_10-36-07.tdms	Attribute	Value
	Loss (USD/a)	256.78	
	Leak rate (cfm)	.57633	
	Level (dB)	91.3	
	Pressure (psi)	90	
	Distance (ft)	1.00	
	Gas type	Air	
	Machine		
	Component		
	Priority	2	
	Repair recommended	Yes	
	Repair done	No	
	Repairman		
	Repair date		
	Comment Line 2, Section 1. Main manifold.		